

From: Duffy, Vince (DPC)
Sent: Tuesday, 19 September 2017 3:58 PM
To: Committee, Environment (REPS)
Cc: Duffy, Vince (DPC); Rickard, Vicki (DPC); Hawkes, Peter (DPC); Gosling, Chris (DPC)
Subject: Proof Hansard Transcript - Friday, 1 September 2017 - Adelaide

Kathy

Attached is a couple of minor edits to my transcript which are included in the attached email. With regards to the question on notice regarding the impact of high temperatures on the performance of the battery, I am advised that "Large grid connected battery storage systems such as the State's 100 MW battery come with active cooling systems that enable the system to operate across the range of design ambient conditions. As such, in high temperature conditions (e.g. 40C) there is minimal impact on the performance of the battery."

Please feel free to contact me to discuss

Regards

Vince

Vince Duffy

Executive Director

Energy and Technical Regulation

Department of the Premier and Cabinet

L8 11 Waymouth Street, ADELAIDE SA 5000
GPO Box 320, ADELAIDE SA 5001



Government of South Australia
Department of the Premier
and Cabinet

Information contained in this e-mail message may be confidential and may also be the subject of legal professional privilege or public interest immunity. If you are not the intended recipient, any use, disclosure or copying of this document is unauthorised.