



Australian Government

Department of the Environment, Water, Heritage and the Arts

Mr James Catchpole
Committee Secretary
Parliamentary Standing Committee on Public Works
PO Box 6021
Parliament House
CANBERRA ACT 2600

Submission No. 3
(Enoggera Redevelopment)

SL 27/4/08

**RE: ENOGGERA REDEVELOPMENT STAGE ONE,
GALLIPOLI BARRACKS, QUEENSLAND**

Dear Mr Catchpole

Thank you for the opportunity to comment on the Statement of Evidence for the above mentioned works for the Department of Defence.

A review of the Statement of Evidence to the Joint Parliamentary Standing Committee on Public Works has been carried out for compliance with the *Energy in Government Operations* (EEGO) policy.

In consideration of the information provided in the Statement, I am satisfied that there is sufficient intent to comply with the relevant provisions of the EEGO policy with the exception of the following consideration:

- At section 76, the statement outlines that the new Headquarters 7th Brigade building and the Combined mess facility will comply with the minimum energy performance standards in the EEGO policy. It is worth stating that, included in the performance standards under the EEGO policy, is the requirement for a maximum average lighting intensity of 10 watts per square metre.

If you wish to discuss this matter further, please do not hesitate to contact me on (02) 6274 1734 or at lloyd.woodford@environment.gov.au.

Yours sincerely

Lloyd Woodford

Director
Government Energy Efficiency Team
Department of the Environment, Water, Heritage and the Arts

11 April 2008